

2

Chhatrapati Sambhajnagar Municipal Corporation

Fire Department

Telephone No: 2334000-40 | Fax No: 2331444

Outward No /ASHAD/MNP/504/2027

Date: 26/07/2027

To,

National Education Society THU

Hospital Building, Gat No. 90/P,

Mouje Sillod, Taluka Sillod,

District Chhatrapati Sambhajnagar.

**Subject: Regarding Information of Gat No. 90/P,  
National Education Society THU Hospital  
Building.**

Reference:

1. Your letter dated 26/12/2022
2. Provisional Fire NOC issued vide Ref. No. JAK/ASHAD/MNP/1112/2022 dated 27/12/2022
3. Your letter dated 07/04/2025
4. Revised Provisional Fire NOC issued vide Ref. No. JAK/ASHAD/MNP/41/2027 dated 07/04/2027
5. Your letter dated 26/07/2027



Certificate To Be True Translation Of  
Statement 1 of Pg 2  
From Gujarati / Hindi / Marathi To English

With reference to the above, you are hereby informed that your **hospital building** located at Gat No. 90/P, Mouje Sillod, Taluka Sillod, District Chhatrapati Sambhajnagar was issued a Provisional Fire NOC by the Fire Department vide Outward No./ASHAD/MNP/1112/2022 dated 27/12/2022. Based on your documents submitted under Reference 3, a Revised Provisional Fire NOC for **the Hospital and Ayurvedic College Building** was issued vide Outward No./ASHAD/MNP/41/2025 dated 07/04/2025

Therefore, as per Reference 2 Outward No./ASHAD/MNP/41/2025 dated 07/04/2025, we hereby issue the clarification you requested regarding the Provisional Fire NOC dated 27/12/2022 for the hospital building.



Certificate To Be True Translation Of  
Statement 2 of pg 2  
From Gujarati / Hindi / Marathi To English

Sd/-

Chief Fire Officer

Fire Department, Municipal Corporation,  
Chhatrapati Sambhajnagar.



4

छत्रपती संभाजीनगर महानगरपालिका, छत्रपती

अग्निशमन विभाग,

TELEPHONE NO-2334000-40FAX No-2331444

जाक /अशाद/मनपा/ 408/2022

दि. 26 / 07/2022

प्रति,

नॅशनल एज्युकेशन सोसायटी थु

हॉस्पिटल बिल्डींग, गट नं ९०/पी,

मौजे सिल्लोड ता सिल्लोड जि. छत्रपती संभाजीनगर.

विषय:- गट नं ९०/पी, नॅशनल एज्युकेशन सोसायटी थु हॉस्पिटल बिल्डींग च्या माहिती बाबत.

संदर्भ:- १. आपले पत्र दि. 26/92/2022

२. जाक/अशाद/मनपा/ 9992//2022 दिनांक 26/92/2022 नुसार प्रोव्हिजनल फायर एन ओ सी देण्यात आलेली आहे.

३. आपले पत्र दि. 08/08/2022

४. जाक/अशाद/मनपा/89//2022 दिनांक 06/08/2022 नुसार रिव्हाईज प्रोव्हिजनल फायर एन ओ सी देण्यात आलेली आहे.

५. आपले पत्र दिनांक 26/06/2022

वरील विषयी आपणास कळविण्यात येते की, आपल्या नॅशनल एज्युकेशन सोसायटी थु हॉस्पिटल बिल्डींग, गट नं ९०/पी, मौजे सिल्लोड ता सिल्लोड जि. छत्रपती संभाजीनगर या इमारतीस अग्निशमन विभागाकडून जाक/ अशाद/ मनपा/ 9992/ 2022 दिनांक 26/92/2022 नुसार प्रोव्हिजनल फायर एन ओ सी देण्यात आलेली असून आपल्या संदर्भ ३ च्या कागदपत्राच्या विनंतीवरून हॉस्पिटल अँड आयुर्वेदिक कॉलेज बिल्डींग करीता जाक/ अशाद/ मनपा/ 89/ 2022 दिनांक 06/ 08/ 2022 नुसार रिव्हाईज प्रोव्हिजनल फायर एन ओ सी देण्यात आलेली आहे.

संबंधीतास संदर्भ क्र ०२ नुसार हॉस्पिटल बिल्डींग करीता जाक/ अशाद/ मनपा /9992 /2022 दिनांक 26/92/2022 नुसार अग्निशमन विभागाकडून प्रोव्हिजनल फायर एन ओ सी देण्यात आलेली आहे. करीता आपण मागणी केलेली माहिती देण्यात येत आहे.

मुख्य अग्निशमन अधिकारी,  
अग्निशमन विभाग, महानगरपालिका,  
छत्रपती संभाजीनगर



5

General Receipt

12815

Book No.: ~~नॅशनल मायुवेदीकु, 60 बडस~~ Receipt No.: ~~सॅस्पिटल विल्डींग & मायुवेदीकु कॉलेज, बडके नं 89/सी,~~

Received from Shri/Shrimati ~~सिल्लोड, ता. सिल्लोड, जि. छ. संभाजीनगर~~  
a sum of Rs. ~~20,000/-~~ (in words) ~~वीस हजार रुपये~~

on account of ~~रिहार्ड प्रो. की जनल N/C फीस.~~

Date: ~~07/4/2024~~

Signature of Clerk

Entered in Cash Book



*[Signature]*  
मुख्य अभियंता/उप-अभियंता  
Dy. Commissioner  
अभिवादन विभाग व अभियंता सेवा  
संभाजीनगर नगरपालिका संभाजीनगर



**Chhatrapati Sambhajinagar Municipal Corporation**  
**FIRE BRIGADE**  
**TELEPHONE NO-2334000-40FAX No-2331444**

Outward No:AMC/FIRE / 41 /2025

Date 07 / 04/2025

To,  
**National Ayurvedic 60 Bedded Hospital Building**  
**And Ayurvedic College, S. No. 89/P, 90/P,**  
**At. Sillod tq. Sillod Dist. Chhatrapati Sambhajinagar.**

**Sub:- Revise Provisional Fire NOC is issued to the National Ayurvedic 60 Bedded Hospital Building & Ayurvedic College, S. No. 89/P, 90/P, At. Sillod tq. Sillod Dist.Chhatrapati Sambhajinagar.**

**Ref:- 1) Your Letter on date 26/12/2022 2) Provisional Fire Noc on date 27/12/2022**  
**3) Your Letter on date 05/04/2025 4) CFO Inspection on date 05 /04/2025**

With Reference to the above subject **Revise Provisional Fire NOC is issued to the National Ayurvedic 60 Bedded Hospital Building And Ayurvedic College, S. No. 89/P, 90/P, At. Sillod tq. Sillod Dist. Chhatrapati Sambhajinagar. Plot area is 8900.00 Sq.mtr.**

Owner has paid **Revise Provisional Noc fees Rs 20,000/-** in Fire brigade Receipt No.12815 date on.07/04/2025

S. No	Building Type	Height of Building	No. of Building	Floors	Area of Plot	Builtup of Area Sq.Mtr	Noc Fees Rs	Total Rs.
1	60 Bedded Hospital & Ayurvedic College Building	13.80 Mtr	1	B/G+2 (IPD) OPD, PEB Ward	8900.00	4605.46	20000	20000
							20000	20000

Following Fire prevention and Fire protection & Fire Fighting measures subject to the **60 Bedded Hospital & Ayurvedic College Building shall be provided.**

1. Open space all around the building shall be provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Underground water tank 100000 lit. & Overhead water tank 10000 lit capacity with the Main fire pump-16200 LPM-01 Nos & Jockey Pump -180 LPM-01 Nos capacity for building shall be provided.
3. Fire service inlet 4 way incoming shall be provided.
4. Yard Hydrant points all around the building with fire hose pipe/ branch shall be provided.
5. Wet-riser having outlet on all floors with hose pipe / branch shall be provided.
6. Hose reel of 100 feet on all outlets shall be provided.
7. Fire Extinguisher of / ABC/ Co2/ Fire Buckets of suitable capacity / quantity & Fire Chut shall be provided.
8. Automatic Sprinkler system / Manually Operated Electric fire alarm system / Automatic Detection system shall be provided.
9. All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency.
10. It shall be ensured that security staff & every employees of the building are trained in handling fire fighting equipments & fire fighting.
11. Fire Extinguisher, **Fire Bucket, Danger, No Smoking**, Caution boards should be displayed at the places physically shown & the caution boards should be easily visible from a distance.
12. The Fire Safety requirements of IS 3594 i.e. Code of practice fore fire safety of Highrise Building shall be followed.

Telephone numbers like **Police, Fire Brigade, Hospital, Doctors**, should be security cabin & Office of the building.

ies of TATA Zenith or APL (APPOLO) or ISI Mark for Fire Down comer system  
ided

requirements shall be carried out with prior approval from fire Brigade.

**ing System arrangements installed for Existing area, such as Hydrant System, Hose  
inguishers, Wet Riser, Manually Operated Fire Alarm System, Fire Pumps, Automatic  
n System should be extended to the proposed construction and also integrated with**

Fighting n	Requirements	Provision	Remarks
Fire ers	Required	IS: 15683 & IS: 2190	Portaable Fire Extinguisher should be installed Confirming to IS 15683 & Other I.S Codes
	Required Prominent Places	At Varous Strategic Locations	On each floor in the Staircase landing for fire fighting. The first aid hose reel shall be connected directly to riser/Down comer main and diameter of the hose reel shall not be less than 19 mm Confirming to IS 884:1985
Hydrant Hydrant ound the	Required around all proposed building	Fire Brigade inlet connection should be provided. Hydrant points should be provided with of Dilivery Hose Confirming to IS-636 along with standard Branch. The distance between 2 Hydrants should not be more than 30 Mtrs. The quidelines should be followed as per IS 3844:1989 & IS 13039:2012	
Operated System	Required	At every Floor on strategic location	Manually operated Fire Alarm Should be provided, It should be connected to alternate power supply.
rd e Tank	Tank	This Water Storage should be exclusively for Fire Fighting	
'ump ump & np	Pumps shall be used	Fire Fighting pumps shall be well maintained. A Separate arrangement of pumping should be done for Sprinkler system.All the Fire pumps must be centrifugal pumps only.	
Smoke ystem & System	Required in entire building ( If false ceiling voids exceeding 800 mm of Height aboce false detection system should be provided.	Automatic Smoke Detection system should be provided. Standards and guidelines given in IS: 11360-1985 specification for smoke detectors for use in automatic Electrical fire Alarm System & IS 2189-2008 Selection Installation and Maintenance of Automatic Fire Detection And Alarm System should Be followed.	
Sprinkler	Required in provosed Structure and Fire Pump Room ( If False Celking Volds Exceeding 800 mm of Height above false celling sprinkler should be provided)	Separate Pumping arrangement should be provided for the sprinkler system. Guidelines are given in IS: 15105 Design and installation of Fixed Automatic sprinkler Fire Extinguising system.	
itors for ety Safe of in case y signs	Required at Prominent Places in all building	Sign Indicators should provided at prominent places as per the guidelines given in IS 9457 for Safety colour and safety IS: 12349 For Fire Protection Safety Signs IS: 12407 for Graphics symbots for Fire Protection Plan.	

(A)

10	Fire Brigade Connection	Required at the main Gate and on Fire Water Tank	For Static Water Tank and For Hydrant System
----	-------------------------	--	--

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006. **Revise Provisional Fire NOC is issued to the National Ayurvedic 60 Bedded Hospital Building And Ayurvedic College, S. No. 89/P, 90/P, At. Sillod tq. Sillod Dist. Chhatrapati Sambhajanagar.**

  
Chief Fire Officer  
Fire Brigade, Municipal Corporation,  
Chhatrapati Sambhajanagar.

Copy to:- A D.T.P AMC, Chhatrapati Sambhajanagar.